

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No. F.6/DFS/MS/School/2023/SZ/ 144

Dated 27.02.2023

**FIRE SAFETY CERTIFICATE**

Certified that the **General Raj's School**, located at Hauz Khas, New Delhi- 110016 comprised of two Blocks- Ground plus two upper floors and basement, ground plus three upper floors owned/occupied by General Raj's School was issued FSC by this department vide letter no. F6/DFS/MS/School/2019/SZ/2326 Dated 16-12-2019. The premises was re-inspected by officers concerned of this department on 16/02/2023 in presence of Mr. Santosh (Manager) and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the 27/02/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/02/ 2023 at New Delhi by

  
(SUNIL CHAUDHARY)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, General Raj's School, located at Hauz Khas, New Delhi- 110016
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.